



# Certificate of Compliance

**POLYETHYLENE (PE) PLASTIC PIPE  
POLYPIPE PW IN CLASS 150 AND 200 (150 AND 200 PSI)  
FOR UNDERGROUND FIRE PROTECTION SERVICE**

**Pressure Class 150 (150 PSI)**

4, 6, 8, 10, 12, 14, 16, 18, 20, 22 and 24 inch PC 150

**Pressure Class 200 (200 PSI)**

4, 6, 8, 10, 12, 14, 16, 18, 20 and 24 inch PC 200

**Manufactured by: PolyPipe, Inc.  
2406 N. I-35  
Gainesville, Texas 76240  
USA**

FM Approvals confirms that the items have been found to comply with the FM Approvals Standard Class Number 1613.

Project Identifier: 3034419

Report dated: December 17, 2008

A handwritten signature in black ink, appearing to read 'Richard B. Dunne', written over a horizontal line.

Richard B. Dunne  
Group Manager-Hydraulics

December 18, 2008  
Date



Member of the FM Global Group